State of North Carolina
Department of Environment,
Health and Natural Resources
Winston-Salem Regional Office

James B. Hunt, Jr., Governor Jonathan B. Howes, Secretary Leesha Fuller, Regional Manager



Dug 31, 1993

P.C. Div. of Forest Res. P.D. Box 57687 Rollige no 27611
Dear <u>Sir.</u>
This letter is to acknowledge your Notification of Tank Closure as received future correspondence must contain the file name as well as address and county in the subject to ensure its receipt into our filing system.
The results of the required assessment (NCAC Title 15A Subchapter 2N

The results of the required assessment (NCAC Title 15A Subchapter 2N Section .0803 and 40 CFR Part 280.72) should be submitted to this office no later than thirty (30) days after the tank is closed. If there is evidence of a release or suspected release, it must be reported within twenty-four (24) hours.

Also, please remember that to permanently close a tank, owners and operators must empty and clean it by removing all liquids and accumulated sludges as required under 15A 2N .0802 and 40 CFR 280.71(b).

If a specific date for tank closure was not noted on the UST-3 form, then a specific date must be given 5 - 7 working days prior to tank closure.

Groundwater Section staff will be conducting random site visits to ensure that underground storage tank closures are conducted as required in 15A 2N .0802 and .0803 and 40 CFR 280.71 and 280.72. Any violations documented may be submitted for enforcement action.

Enclosed is an attachment that is to be used for the information required for closure assessment. You may contact me at the letterhead address or telephone number if you have any questions concerning these requirements.

Sincerely,

W. Wachell Watters Waddell Watters Hydrogeologist II

Enclosu**re**

WSRO Locking & Boberton Inc

8025 North Point Boulevard, Suite 100, Winston -Salem, North Carolina 27106-3203
Telephone 919-896-7007 FAX 919-896-7005

An Equal Opportunity Affirmative Action Employer

50% recycled/ 10% post-consumer paper